

PREISOLATI

INSULATED TERMINALS - COSSES ISOLÉES - ISOLIERTE KABELSCHUHE



DISEGNO DRAWING DESSIN ZEICHNUNG	SEZIONE CAVO CABLE SECTION SECTION DU CÂBLE KABEL QUERSCHNITT mm ²	Øi mm	Øe mm	L mm	L1 mm	SPESSORE THICKNESS ÉPAISSEUR DICKE mm	MATERIALE MATERIAL MATÉRIEL WERKSTOFF	REF.	PCS
	0.25÷1 35000103	3.2	5.5	18	10.5	0.75	Cu-Sn PA 66	18.53050 18.53059	100 4000
	0.25÷1	3.7	5.5	18	10.5	0.75	Cu-Sn PA 66	18.53060 18.53069	100 4000
	0.25÷1 35000104	4.3	6.6	20.1	10.5	0.75	Cu-Sn PA 66	18.53070 18.53079	100 4000
	0.25÷1 35000105	5.3	8	21.5	10.5	0.75	Cu-Sn PA 66	18.53150 18.53159	100 4000
	0.25÷1 35000106	6.4	11.6	27.4	10.5	0.75	Cu-Sn PA 66	18.53200 18.53209	100 4000
	0.25÷1 35000108	8.4	11.6	27.4	10.5	0.75	Cu-Sn PA 66	18.53250 18.53259	100 4000
	1÷2.5 35000203	3.2	6.6	18.6	11	0.8	Cu-Sn PA 66	18.57050 18.57059	100 4000
	1÷2.5	3.7	6.6	18.6	11	0.8	Cu-Sn PA 66	18.57060 18.57069	100 4000
	1÷2.5 35000204	4.3	8.5	23	11	0.8	Cu-Sn PA 66	18.57100 18.57109	100 4000
	1÷2.5 35000205	5.3	8.5	23	11	0.8	Cu-Sn PA 66	18.57150 18.57159	100 4000
	1÷2.5 35000206	6.4	12	28	11	0.8	Cu-Sn PA 66	18.57200 18.57209	100 4000
	1÷2.5 35000208	8.4	12	28	11	0.8	Cu-Sn PA 66	18.57250 18.57259	100 4000
	2.5÷6 35000304	4.3	7.2	23.5	14	1	Cu-Sn PA 66	18.63100 18.63109	50 3000
	2.5÷6 35000305	5.3	9.5	27	14	1	Cu-Sn PA 66	18.63150 18.63159	50 3000
	2.5÷6 35000306	6.4	12	30.5	14	1	Cu-Sn PA 66	18.63200 18.63209	50 2000
	2.5÷6 35000308	8.4	15	35.2	14	1	Cu-Sn PA 66	18.63250 18.63259	50 2000
	2.5÷6 35000310	10.4	15	35.2	14	1	Cu-Sn PA 66	18.63300 18.63309	50 500